

Summary of assessment*

Clause	Assessment
7.3 Visual inspection	Pass
7.5 Material	Pass
7.8 Finish of parts	Pass
7.9.1 Total inward leakage	Pass
7.9.2 Penetration of filter material	Pass
7.12 Carbon dioxide content of the inhalation air	Pass
7.16 Breathing resistance	Pass

Key

Pass	Requirement satisfied.
NRq	The clauses were not required.
Fail	Requirement not satisfied. Refer to the "Result details" section for more information.
N.A.	Assessment not carried out.

* Assessment relates only to those specimens which were tested and are the subject of this report.

Test Result

Respiratory Protective Devices — Filtering Half Masks to Protect against Particles — Requirements, Testing, Marking
(EN 149:2001+A1:2009)

Clause 7.3 Visual inspection

Test Requirement	Results	Comment
Marking and the information supplied by the manufacturer, requirements refer to clause 9 and clause 10.	Comply	Pass

Clause 7.5 Material

(EN 149:2001+A1:2009, Clause 8.2 & 8.3.1 & 8.3.2)

Test Requirement	Results	Comment
Materials used shall be suitable to withstand handling and wear over the period for which the particle filtering half mask is designed to be used.	Comply	Pass
After undergoing the conditioning described in 8.3.1 none of the particle filtering half masks shall have suffered mechanical failure of the face piece or straps.	Comply	Pass
When conditioned in accordance with 8.3.1 and 8.3.2 the particle filtering half mask shall not collapse.	Comply	Pass
Any material from the filter media released by the air flow through the filter shall not constitute a hazard or nuisance for the wearer.	Comply	Pass

Clause 7.8 Finish of Parts

EN 149:2001+A1:2009, Clause 8.2)

Test Requirement	Results	Comment
Parts of the device likely to come into contact with the wearer shall have no sharp edges or burrs.	No sharp edges or burrs	Pass

Clause 7.9.1 Total Inward Leakage
(EN 149:2001+A1:2009 Clause 8.5)

Test Requirement	Results	Comment
<p>For particle filtering half masks fitted in accordance with the manufacturer's information, at least 46 out of the 50 individual exercise results (i.e. 10 subjects x 5 exercises) for total inward leakage shall be not greater than:</p> <p style="padding-left: 40px;">25% for FFP1 11% for FFP2 5% for FFP3</p> <p>and, in addition, at least 8 out of the 10 individual wearer arithmetic means for the total inward leakage shall be not greater than:</p> <p style="padding-left: 40px;">22% for FFP1 8% for FFP2 2% for FFP3</p>	<p>Detail refer to Appendix 1</p>	<p>Pass</p>

Appendix 1: Summarization of Test Data

Subject	Sample	Condition	Normal Breathing (%)	Head Side/Side (%)	Head Up/Down (%)	Speak Loudly (%)	Normal Breathing (%)	Mean (%)
Huang	1#	A.R.	0.8	1.0	1.0	1.1	0.9	0.96
Zhou	2#	A.R.	1.2	1.4	1.5	1.7	1.1	1.38
Ma	3#	A.R.	1.1	1.5	1.3	1.8	1.2	1.38
Wu	4#	A.R.	0.7	1.2	1.0	1.3	0.8	1.00
Li	5#	A.R.	1.0	1.1	1.2	1.4	1.1	1.16
Wu	6#	T.C.	1.5	1.7	1.9	2.2	1.6	1.78
Zhai	7#	T.C.	1.3	1.5	1.6	1.8	1.2	1.48
Zheng	8#	T.C.	1.0	0.9	0.8	1.2	1.1	1.00
Huang	9#	T.C.	1.4	1.7	1.7	1.9	1.5	1.64
Wu	10#	T.C.	1.2	1.4	1.4	1.6	1.3	1.38

Facial Dimension:

Subject	Length of Face (mm)	Width of Face (mm)	Depth of Face (mm)	Width of Mouth (mm)
Huang	130	140	125	53
Zhou	100	148	125	55
Ma	120	158	110	50
Wu	110	148	121	44
Li	112	146	112	50
Wu	120	154	128	54
Zhai	135	165	125	53
Zheng	106	155	112	54
Huang	105	157	118	51
Wu	112	172	118	55

Clause 7.9.2 Penetration of Filter Material

(EN 149:2001+A1:2009, Clause 8.11 & EN 13274-7:2019)

Test Requirement			Results	Comment
The penetration of the filter of the particle filtering half mask shall meet the requirements of the following table.			Detail refer to Appendix 2	Pass
Classification	Maximum penetration of test aerosol (%)			
	Sodium chloride test 95 L/min	Paraffin oil test 95 L/min		
FFP1	20	20		
FFP2	6	6		
FFP3	1	1		

Appendix 2: Summarization of Test Data

Penetration of filter material

Aerosol	Condition	Sample No.	Penetration (%)		Assessment
			Average in 30s after 3 min	Max. during exposure	
Sodium chloride test	A.R.	14#	0.1	/	Pass
		15#	0.1	/	
		16#	0.1	/	
	S.W.	20#	0.3	/	
		21#	0.1	/	
		22#	0.1	/	
	M.S. + T.C.	26#	/	0.7	
		27#	/	0.8	
		28#	/	0.8	
	Paraffin oil test	A.R.	11#	0.5	
12#			0.4	/	
13#			0.3	/	
S.W.		17#	0.4	/	
		18#	0.4	/	
		19#	0.4	/	
M.S. + T.C.		23#	/	0.3	
		24#	/	0.3	
		25#	/	0.3	
Flow conditioning: 95.0 L/min					

Clause 7.12 Carbon Dioxide Content of The Inhalation Air

(EN 149:2001+A1:2009, Clause 8.7)

Test Requirement	Results	Comment
The carbon dioxide content of the inhalation air (dead space) shall not exceed an average of 1,0 % (by volume)	Detail refer to Appendix 4	Pass

Appendix 4: Summarization of Test Data
Carbon Dioxide Content of The Inhalation Air

Condition	Sample No.	Result		Assessment
A.R.	29#	0.28%	Mean value 0.27%	Pass
	30#	0.28%		
	31#	0.25%		

Clause 7.16 Breathing Resistance
EN 149:2001+A1:2009, Clause 8.9)

Test Requirement				Results	Comment
The breathing resistances apply to valved and valveless filtering half masks and shall meet the requirements as the following table.				Detail refer to Appendix 5	Pass
Classification	Maximum permitted resistance (mbar)				
	Inhalation		Exhalation		
	30 L/min	95 L/min	160 L/min		
FFP1	0.6	2.1	3.0		
FFP2	0.7	2.4	3.0		
FFP3	1.0	3.0	3.0		

Appendix 5: Summarization of Test Data

Specimen	Condition	Inhalation		Exhalation resistance(mbar)				
		At 30 L/min	At 95 L/min	At 160 L/min				
				A	B	C	D	E
32#	A.R.	0.5	1.8	2.3	2.3	2.2	2.3	2.3
33#		0.5	1.8	2.3	2.3	2.3	2.3	2.3
34#		0.5	1.8	2.4	2.3	2.3	2.3	2.3
35#	S.W.	0.6	1.9	2.4	2.4	2.4	2.5	2.5
36#		0.6	1.9	2.4	2.4	2.4	2.3	2.4
37#		0.6	1.9	2.4	2.4	2.4	2.4	2.4
38#	T.C.	0.5	1.6	2.2	2.2	2.2	2.2	2.2
39#		0.5	1.6	2.2	2.2	2.2	2.2	2.2
40#		0.5	1.6	2.3	2.2	2.2	2.2	2.3
/	T.C.+F.C.	/	/	/	/	/	/	/
/		/	/	/	/	/	/	/
/	F.C.	/	/	/	/	/	/	/

A: facing directly ahead; B: facing vertically upwards; C: facing vertically downwards; D: lying on the left side; E: lying on the right side

Sample photo(s):



Fig.1



Fig.2




Fig.3




Fig.4



Fig.5

****End of Report****

The test report is effective only with both signature and specialized stamp, the result(s) shown in this report refer only to the sample(s) tested. Without written approval of NTEK, this report can't be reproduced except in full.